

Certificate Of Analysis

Certificate Number: **0035-25** Issue Number: **1** Issue Date: **24/04/2025 12:03:06 PM**
Test Certificate for: **Flyash Blend 25**
Sample Tested at: **Sunstate Cement Ltd., Port of Brisbane, Australia**
Sample Identification: **Spot Despatch Sample F6P-001986 dated 3/02/2025**
Sample Produced at: **Sunstate Cement Ltd., Port of Brisbane, Australia**

SPECIFIC PROPERTY	TEST METHOD	AS3972 REQUIREMENTS		RESULT
Compressive strength	AS2350.11, AS2350.12			
3 Day				28 MPa
7 Day		Minimum	35 MPa	40.4 MPa
28 Day		Minimum	45 Mpa	56.7 MPa
Setting Time	AS2350.4			
Initial		Minimum	45 mins	105 mins
Final		Maximum	360 mins	180 mins
Soundness	AS2350.5	Maximum	5 mm	1 mm
Sulphuric anhydride (SO₃)	In House	Maximum	3.5 %	2.1 %
Chloride	AS3583.13	Maximum	0.1 %	0.022 %
REPORTABLE PROPERTY	TEST METHOD			RESULT
Loss on ignition	AS2350.2			2.1 %
Fineness	AS2350.8			440 m ² /kg
OTHER PROPERTIES	TEST METHOD			RESULT
Normal Consistency	AS2350.3			31.2 %

Sampling Procedure:

Samples were prepared in accordance with AS2350.1

Remarks:

- 1 These results only relate to the specimens identified on this report
- 2 The sample as tested conforms to the requirements of AS3972 as Type GB cement
- 3 The blended cement is produced with as nominal 25% fly ash content



NATA accredited
Laboratory Number: 2191

Accredited for compliance with
ISO/IEC 17025 Testing



George Santagiuliana
Approved Signature

24/04/2025

This certificate replaces previous certificate number 0035-25, issue 0 dated (REASON: Test Data Updated)