

Certificate Of Analysis

Certificate Number: **0506-24** Issue Number: **1** Issue Date: **24/04/2025 12:14:58 PM**
Test Certificate for: **Slag Blend 60**
Sample Tested at: **Sunstate Cement Ltd., Port of Brisbane, Australia**
Sample Identification: **Spot Despatch Sample H6P-000829 dated 25/11/2024**
Sample Produced at: **Sunstate Cement Ltd., Port of Brisbane, Australia**

SPECIFIC PROPERTY	TEST METHOD	AS3972 REQUIREMENTS		RESULT
Compressive strength	AS2350.11, AS2350.12			
3 Day				18.0 MPa
7 Day		Minimum	20 MPa	29.4 MPa
28 Day		Minimum	35 Mpa	49 MPa
Setting Time	AS2350.4			
Initial		Minimum	45 mins	150 mins
Final		Maximum	600 mins	225 mins
Soundness	AS2350.5	Maximum	5 mm	0 mm
Sulphuric anhydride (SO₃)	In House	Maximum	3.5 %	2.2 %
Chloride	AS3583.13	Maximum	0.1 %	0.007 %
REPORTABLE PROPERTY	TEST METHOD			RESULT
Loss on ignition	AS2350.2			0.7 %
Fineness	AS2350.8			450 m²/kg
OTHER PROPERTIES	TEST METHOD			RESULT
Normal Consistency	AS2350.3			33.2 %

Sampling Procedure:

Samples were prepared in accordance with AS2350.1

Remarks:

- 1 These results only relate to the specimens identified on this report



NATA accredited
Laboratory Number: 2191

Accredited for compliance with
ISO/IEC 17025 Testing



George Santagiuliana
Approved Signature
24/04/2025

This certificate replaces previous certificate number 0506-24, issue 0 dated (REASON: Test Data Updated)