

CERTIFICATE OF ANALYSIS

CERTIFICATE No. 1026-19

TEST CERTIFICATE FOR: GP Portland Cement

PRODUCED AT: Sunstate Cement Ltd, Port of Brisbane

SAMPLE IDENTIFICATION: Spot Despatch Sample sample A6P-002361 sampled on 29/7/2019

SAMPLE TESTED AT: Sunstate Cement Ltd, Port of Brisbane

| SPECIFIED PROPERTY | TEST METHOD | AS3972 REQUIREMENTS | | RESULT |
|----------------------------------------|----------------------|---------------------|----------|----------|
| Compressive strength | AS2350.11, AS2350.12 | | | |
| 3 day | | | | 33.8 MPa |
| 7 day | | Minimum | 35 MPa | 47.8 MPa |
| 28 day | | Minimum | 45 MPa | 62.9 MPa |
| Setting time | AS2350.4 | | | |
| Initial | | Minimum | 45 mins | 105 mins |
| Final | | Maximum | 360 mins | 180 mins |
| Soundness | AS2350.5 | Maximum | 5 mm | 2 mm |
| Sulphuric anhydride (SO ₃) | In House | Maximum | 3.5 % | 2.9 % |
| Chloride | AS3583.13 | Maximum | 0.1 % | 0.003 % |


| REPORTABLE PROPERTY | TEST METHOD | | | RESULT |
|-------------------------------------------------|-------------|--|--|------------------------|
| Loss on ignition | AS2350.2 | | | 3.9 % |
| Fineness | AS2350.8 | | | 365 m ² /kg |
| Total Alkali (Na ₂ O _{eq}) | AS2350.2 | | | 0.4 % |

| OTHER PROPERTIES | TEST METHOD | | | RESULT |
|--------------------|-------------|--|--|--------|
| Normal Consistency | In House | | | 28.0 % |

SAMPLING PROCEDURE:

- The results of the above tests relate only to the sample as described above.
- Total Alkali determined at Australian Laboratory Services by ICP -AES using ME -ICP 91, Corporate Accreditation No 825, Corporate Site 818.

REMARKS:



G Santaguiliana
Approved Signatory
3-Sep-2019

Page 1 of 1

A.B.N. 58 010 421 879
 POSTAL ADDRESS: PO BOX 350, WYNNUM, QLD. 4178
 PHONE: (07) 3895 9800 FAX: (07) 3895 9801



NATA accredited laboratory
 Laboratory Number: 2191
 Accredited for compliance with
 ISO/IEC 17025

The results of the tests,
 calibrations and/or measurements
 included in this document are
 traceable to Australian/national
 standards. This document shall not
 be reproduced except in full.