

# Certificate Of Analysis

Certificate Number: **0003-21** Issue Number: **1** Issue Date: **12/02/2021 3:07:08 PM**  
 Test Certificate for: **SUNLITE Cement**  
 Sample Tested at: **Sunstate Cement Ltd., Port of Brisbane, Australia**  
 Sample Identification: **Spot Despatch Sample L6P-001340 dated 4/01/2021**  
 Sample Produced at: **Sunstate Cement Ltd., Port of Brisbane, Australia**

SPECIFIC PROPERTY	TEST METHOD	AS3972 REQUIREMENTS		RESULT
<b>Compressive strength</b>	AS2350.11, AS2350.12			
3 Day		Minimum	25 MPa	<b>43.5 MPa</b>
7 Day		Minimum	40 Mpa	<b>49.4 MPa</b>
28 Day				<b>55.1 MPa</b>
<b>Setting Time</b>	AS2350.4			
Initial		Minimum	45 mins	<b>90 mins</b>
Final		Maximum	360 mins	<b>135 mins</b>
<b>Soundness</b>	AS2350.5	Maximum	5 mm	<b>1 mm</b>
<b>Sulphuric anhydride (SO<sub>3</sub>)</b>	In House	Maximum	3.5 %	<b>3.1 %</b>
<b>Chloride</b>	AS3583.13	Maximum	0.1 %	<b>0.020 %</b>
REPORTABLE PROPERTY	TEST METHOD			RESULT
Loss on ignition	AS2350.2			<b>4.9 %</b>
Fineness	AS2350.8			<b>460 m<sup>2</sup>/kg</b>
OTHER PROPERTIES	TEST METHOD			RESULT
Normal Consistency	AS2350.3			<b>29.3 %</b>

**Sampling Procedure:**

Samples were prepared in accordance with AS2350.1

**Remarks:**

- 1 These results only relate to the specimens identified on this report



NATA accredited  
 Laboratory Number: 2191

Accredited for compliance with  
 ISO/IEC 17025 Testing



George Santagiuliana  
 Approved Signature

12/02/2021

***This certificate replaces previous certificate number 0003-21, issue 0 dated (REASON: Test Data Updated)***